

DSDS Duct Smoke Delivery System Specification

DUCT DETECTOR TEST DEVICE

1. Each duct smoke detector shall have a DSDS, or equal, testing device installed per manufacturer's instructions.
2. Duct smoke detector shall not have a key or magnet operated test switch.
3. Each duct smoke detector shall have a remote alarm annunciator installed per local building code.
4. DSDS test device is available from LifeSafetytest.com